



NOTES:

1. PROVIDE PROTECTION FROM ALL VEHICLE TRAFFIC, EQUIPMENT STAGING, AND FOOT TRAFFIC IN PROPOSED INFILTRATION AREAS PRIOR TO, DURING, AND AFTER CONSTRUCTION.
2. DIMENSIONS:
 - WIDTH: 30" MINIMUM
 - DEPTH OF PLANTER (FROM TOP OF GROWING MEDIUM TO OVERFLOW WEIR ELEVATION): 12"
 - SLOPE OF PLANTER: 0.5% OR LESS
3. PLANTER MUST BE SETBACK A MINIMUM OF 5 FEET FROM PROPERTY LINE.
4. OVERFLOW WEIR ELEVATION MUST ALLOW FOR 4" OF FREEBOARD, MINIMUM. SIZE OVERFLOW WEIR FOR THE 100 YEAR DESIGN STORM. IDENTIFY EMERGENCY OVERFLOW ROUTE ON THE STORMWATER MANAGEMENT PLAN.
5. DRAIN ROCK SIZE: 1 1/2" - 3/4" WASHED WITH MINIMUM 28" DEPTH.
6. SEPARATION BETWEEN DRAIN ROCK AND GROWING MEDIUM SHALL BE A 3" LAYER OF 3/4" - 1/4" OPEN GRADED AGGREGATE.
7. GROWING MEDIUM WILL BE A MINIMUM 18" DEPTH. FACILITY SURFACE AREA MAY BE REDUCED BY 20% WHEN GROWING MEDIA DEPTH IS INCREASED TO 30" OR MORE.
8. VEGETATION WILL FOLLOW THE LANDSCAPE PLANS.
9. PLANTER WALL MATERIAL SHALL BE STONE, BRICK, CONCRETE OR OTHER DURABLE MATERIAL AND SHALL BE INCLUDED ON FOUNDATION PLANS. INSTALL INVERTED CURB AS NEEDED BETWEEN PLANTERS AND ROAD SUBGRADE. WALL HEIGHTS GREATER THAN 24" ABOVE GRADE REQUIRE HANDRAILS. SUBMIT RETAINING WALL DESIGN IN ACCORDANCE WITH APPLICABLE STRUCTURAL CODES FOR REVIEW AND APPROVAL.
10. WATERPROOF LINER SHALL BE 30 MIL PVC OR EQUIVALENT. A WATERPROOF LINER IS NOT REQUIRED IF THE WALL MATERIAL IS WATERPROOF REINFORCED CONCRETE OR APPROVED EQUAL.
11. INSTALL CONCRETE SPLASH PAD TO TRANSITION FROM INLET TO GROWING MEDIUM. SIZE OF PAD SHALL BE 1 FT X 1 FT.
12. SEASONAL HIGH GROUNDWATER SEPARATION DISTANCE AS REQUIRED.

NO.	REVISIONS	DATE	BY
1			
2			
3			
4			