



NOTES:

1. 4" LATERALS MUST HAVE 4" CLEAN OUT RISERS, AND 6" LATERALS MUST HAVE 6" CLEAN OUT RISERS.
2. THE CLEAN OUT RISER MUST BE LOCATED WITHIN 6" OF THE PROPERTY LINE AND JUST INSIDE THE ROAD RIGHT OF WAY OR THE OLWS EASEMENT. THE CLEAN OUT RISERS MAY NOT BE LOCATED ON PRIVATE PROPERTY OR IN A PUBLIC UTILITY EASEMENT.
3. THE LATERAL MUST BE INSTALLED WITH A MINIMUM GRADE OF 2% AND MUST RUN PERPENDICULAR FROM THE MAIN TO THE CLEAN OUT.
4. THE CLEAN OUT RISER MUST BE TOPPED WITH A PVC CLEAN OUT ADAPTER WITH A THREADED PLUG.
5. THE CLEAN OUT MUST BE PROTECTED BY A TRAFFIC RATED BOX. EITHER A CAST IRON UNIT OR A COMBINATION CONCRETE AND CAST IRON UNIT IS ACCEPTABLE.
6. OLWS MAY REQUIRE THE TV INSPECTION OF A LATERAL AFTER BACKFILL AND COMPACTION.

NO.	REVISIONS	DATE	BY
1	MISC CALLOUTS, DIMS, AND NOTES	1/9/2019	HSO
2	NOTE CORRECTIONS	3/5/2024	TAP
3			
4			