



**NOTES:**

1. TAPPING SLEEVE SHALL BE STAINLESS STEEL MECHANICAL SLEEVE.
2. CONNECTIONS TO EXISTING MAIN SHALL BE PERFORMED UNDER THE DIRECT SUPERVISION OF OLWS AND WILL NOT BE ALLOWED ON FRIDAYS, HOLIDAYS OR WEEKENDS. VALVES SHALL BE OPERATED BY OLWS ONLY.
3. 11 MIL PLASTIC OR CONSTRUCTION FABRIC SHALL BE WRAPPED AROUND PIPE AND FITTINGS BEFORE THRUST BLOCK IS POURED.
4. SUPPORT VALVE AND SLEEVE CONTINUOUSLY THROUGH INSTALLATION.
5. TEST TAPPING SLEEVE PRIOR TO CUTTING EXISTING MAIN.

**CUT-IN-TEE**

NO.	REVISIONS	DATE	BY
1	BACKFILL REMOVED, SLEEVE MATERIAL TO SST	1/2/2020	HSD
2			
3			
4			