



## NOTES:

- 1. PIPE ZONE MATERIAL SHALL BE 3/4"-0" CRUSHED ROCK GRANULAR BACKFILL COMPACTED TO 95% OF AASHTO T-99.
- 2. WHEN CROSSING CATHODICALLY PROTECTED SYSTEM, INSTALL PVC SLEEVE
- 3. WHERE NO SIDEWALK EXISTS, PLACE CONCRETE PAD AS SHOWN. WHERE SIDEWALK EXISTS, PLACE MIN. 12" AROUND BACK OF SAMPLE STATION AND INCORPORATE INTO NEW CONCRETE POUR.
- 4. COLOR: STOCK GREEN

